TASK FALL PROTECTION PLAN JOB:			DATE:	
AREA TASK				
HAZARD			By: COMPETENT PERSON	
	FALL PROTECTION - CHOOSE FROM APPROPRIATE OPTIONS			
			der of effectiveness: Choose the most effective possible)	
Exposed To Fall Of 6 Feet at:	Options			
Floor or roof openings and open shafts	·	Opening cover designed to support possible load		
Leading edges and hoist landings		Guardrail system		
Wall openings		Personal Fall Restraint Systems*		
Skylights		Personal Fall Arrest Systems for each worker*		
Exposed to Fall of 6 Feet Anywhere on:	Options			
Roofs without 42" parapet		Guardrail system		
Raised ramps or walkways		Personal Fall Restraint Systems*		
	Personal Fall Arrest Systems for each worker*			
Working Over 6 Feet Above Surface From: Fall Prot			l Protection – Not optional	
Scissor Lift			Work on platform and within guardrails	
Scissor Lift if not protected by guardrails			Personal Fall Arrest System required*	
Boom Lift			Non-Shock absorbing lanyard tied off to basket required	
Supported Scaffold			Construction and guardrails must meet scaffold requirements	
Ladders with no openings nearby			Stay below top step and inside rails	
Ladders within ladder length of openings to 6' fall			Personal Fall Arrest required*	
Ladders if reaching out or standing on upper steps			Personal Fall Arrest required*	
Other - List Fall Protection -		tion	– Must Be Approved By Safety Director	
Plans for Fall Restraint or Fall Arrest System: Type:			Anchor:	
Connection:			Rescue:	

*Personal Fall Restraint or Arrest systems require special training.